

## Appliance Testing Pass Certificate


Client Name	Eugene Portman	CERTIFICATE DATE: 18/09/2006
Address	Semper Fidelis	Wiremill Lane
	Newchapel	Lingfield Surrey
Location Name	Mobile	
	Wiremill Lane	

### TEST RESULTS

Test Date	Appliance	Description	Class/ Voltage	Visual		Earth Continuity	Insulation	Load	Leak.	Flash
				Fuse	Cord					
18/09/2006	000000EP01	MULTI VOLTAGE	2 230	P		S	S >9.90 P	S <0.05 P	0.60 P	S
18/09/2006	000000EP02	IEC MAINS LEAD	1 230	P		0.08 P	S >9.90 P	S <0.05 P	<0.30 P	S
18/09/2006	000000EP02	IEC MAINS LEAD	1 230	P		1.49 P	S >9.90 P	S	S	S
18/09/2006	000000EU03	4 WAY EXTENSION LEAD	1 230	P		0.08 P	S >9.90 P	S <0.05 P	<0.30 P	S
18/09/2006	000000EU04	EXTENSION LEAD	1 230	P		0.25 P	S >9.90 P	S <0.05 P	<0.30 P	S

(P-Pass, S-Skip, F-Fail)

### CONTRACTOR DETAILS

Name	TGR Services		Engineer: Brian Davies BSc Hons BA DipCompOpen
Address	Red Roofs Crowhurst Road		
	Crowhurst		
	Lingfield Surrey RH7 6DG		
Signed			Date 18/9/2006 Valid 4 years

This form was developed by AVO INTERNATIONAL Ltd.